

WATER DEPARTMENT AUGUST 2015 MONTHLY REPORT

Water Supplied this month	12,037,900 gallons
Average Daily Water Supplied	388,319 gallons
Water produced Y.T.D	68,001,800 gallons

Water and Sewer Inspections

- 19 Champions Dr.
- 17 Champions Dr.
- 19 Whistling duck Dr.
- 21 whistling duck Dr.

Sewer Extension Inspections

None this month

New Water Meters and MXU's Installed

308 S. Main St. – 1 meter – replaced bad meter

- 56 Emily Pintail Dr. 1 meter replaced bad meter
- 39 Champions Dr. 2 meters/ 1 mxu
- 21 Champions Dr. 2 meter/1 mxu
- 13 Whistling duck Dr. 1 meter replace bad meter
- 45 Whistling duck 1 meter replace bad meter
- 29 Whistling duck Dr. 2 meters/ 1 mxu
- 152 Widgeon Way 1 meter replace bad meter

Final Readings

- 21 Harlequin Loop
- 37 Harlequin Loop
- 308 S. Main St.
- 47 Canvasback Cir.
- 95 Emily pintail Dr.
- 49 Canvasback Cir.

C.O. Inspections

None this month

Meters removed: 0

Service Calls: 12

Shut-offs: 3

- 1. Water meter readings.
- 2. Routine samples and readings at wells.
- 3. Monthly water samples and usage report for the Office of Drinking Water.
- 4. Performed routine duties and regular maintenance.
- 5. Turned in report for public works time spent at phase 3.
- 6. Meetings with Town Manger.
- 7. Did various Miss Utility locate tickets.
- 8. Mowed grass at well 6, H.S. water tower, and H.S. lift station.
- 9. Sprayed weeds at wells, water tower, and at WWTP.
- 10. Started communication upgrade project.
- 11. USGS at well 2 to calibrate their equipment.
- 12. Repaired fluoride pump at well 6.
- 13. Repaired chlorine injection fitting at well 6.
- 14. Called references for applicants for job opening.
- 15. Interviewed potential candidates for job opening.

Scott Kimball, Superintendent Water Department

Mugnice